Fiber roll in full contact with the ground

Drop inlet grate

SECTION A-A


FIBER ROLL

DROP INLET PROTECTION (TYPE A)


1" x 1" or 1" Ø wood stake. See Note 2


Accumulated sediment


9" Ø (min.) fiber roll



PLAN VIEW - INLET AT SAG








SECTION B-B

GRAVEL BAG BERM **DROP INLET PROTECTION (TYPE B)**

NOTE:

- 1. Select the inlet protection device to fit field conditions as approved by the CO.
- 2. Install fiber rolls with stakes spaced no more than 24-inches on center. Drive stakes 12-inches (min.) in undisturbed soil.
- 3. Approximate finished dimension of gravel bags is 12-inches
- 4. Maximum top of gravel bag spillway elevation = Top of curve minus 1-inch.
- 5. Pack gravel filled bags tightly together end to end to ensure no sediment flows between or underneath the bags. Where tight fit is unachievable, install geotextile filter, class 2, type C along the upstream face of the bags. Place fabric over the top of the bags to the spillway elevation. Anchor the fabric by placing the next layer of bags on top of it. Extend the geotextile fabric a minimum of 18-inches upstream of the bags. Cover geotextile fabric to the top of the fabric with clean, silt-free coarse aggregate between 2-inches and 3-inches in diameter.
- 6. Size the prefabricated filter insert (Type C) to fit the drop inlet and allow collected material removal without spillage. Include a high-flow bypass in the insert.



PREFABRICATED FILTER INSERT DROP INLET PROTECTION (TYPE C) See Note 6

U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION OFFICE OF FEDERAL LANDS HIGHWAY

WFLHD DETAIL

TEMPORARY INLET PROTECTION

Sheet 1 of 2


DETAIL APPROVED FOR USE 7/2016 NO SCALE REVISED:


DETAIL W157-2


| PROJECT | SHEET NUMBER | |
|---------|-----------------|--|
| | | |


NOTE:


- 1. Inlet protection device (type E) may consist of continuous filter tubing filled with gravel or other prefabricated filter material. Install device according to manufacturer's recommendations.
- 2. Vary dimensions to fit field conditions.














SECTION C-C

BLOCK AND GRAVEL DROP INLET PROTECTION (TYPE D1)

BLOCK AND GRAVEL

BLOCK AND GRAVEL
CURB INLET PROTECTION (TYPE D2)

SECTION D-D

SECTION E-E

INLET PROTECTION DEVICE CURB INLET PROTECTION (TYPE E)

U.S. DEPARTMENT OF TRANSPORTATION FEDERAL HIGHWAY ADMINISTRATION OFFICE OF FEDERAL LANDS HIGHWAY

WFLHD DETAIL

TEMPORARY INLET PROTECTION

Sheet 2 of 2

DETAIL APPROVED FOR USE 7/2016 DETAIL REVISED: W157-2

February 2023 7:58 AM

NO SCALE